

DAILY LOG SHEET

Pool Name: _____

Location/Address: _____

POOL or SPA # _____ (circle one)

Month/Year _____

Day	Time	Initials	Free Chlorine Without CYA=1-10ppm with CYA=2-10ppm	pH 7.2-7.8	Max Limit Cyanuric 100 ppm	Spa Temp Max 104 F	Activities Example: filters cleaned, chemicals added, pool closed

Daily Chemical Test Records are required each day the pool/spa is open.



COUNTY OF SONOMA DEPARTMENT OF HEALTH SERVICES
 ENVIRONMENTAL HEALTH & SAFETY
 625 5th Street ❖ Santa Rosa, CA 95404
www.sonoma-county.org/eh
 Phone (707) 565-6565 ❖ FAX (707) 565-6525