



COUNTY OF SONOMA PERMIT AND RESOURCE MANAGEMENT DEPARTMENT

2550 Ventura Avenue, Santa Rosa, CA 95403
(707) 565-1900 FAX (707) 565-1103

NONRESIDENTIAL – ADDITIONS & ALTERATIONS 2010 CALGreen Checklist (Per 7/1/2012 Supplement)

*Applies to Nonresidential Addition and Alteration projects
without sleeping accommodations and meeting the following criteria:*

- The permit application is submitted on or after July 1, 2012 and before the effective date¹ of the 2013 California Building Standards Code; and
- The floor area for the addition (if any) exceeds 2,000² square feet; or
- The permit valuation for the alteration (if any) exceeds \$500,000³.

The provisions of this checklist only apply to the portions of the building being added to or altered within the scope of the permitted work. The provisions of this checklist also apply to all tenant improvement projects meeting the criteria listed above. Newly constructed nonresidential building projects should use the County of Sonoma Nonresidential – 2010 CALGreen+Tier 1 Checklist. Repairs, existing structures not being altered and historic structures are not subject to the requirements of CALGreen.

(This checklist is based on 2010 CALGreen and has been revised to include County of Sonoma requirements.)

Project Address: _____

Project Name: _____

Project Description: _____

Instructions:

1. The Owner or the Owner's agent shall call the PRMD Building Inspection Section at (707) 565-1679 to schedule an on-site preconstruction conference with the PRMD Construction Inspection Supervisor or designee. As a minimum, the Contractor and Owner or Owner's agent shall be present at this meeting. The purpose of this meeting is to discuss the requirements of the work described herein and coordinate submittal of necessary documentation through the progression of the Project.
2. The Owner or the Owner's agent shall ensure the work described herein is completed prior to an inspection request being submitted. A PRMD inspector will verify and assure the Owner that all required work described herein is properly planned and implemented in the project.
3. PRMD staff, in collaboration with the owner and the design professional, shall initially complete **Column 2** of this checklist, sign and date the **CALGreen Building Acknowledgements** section at the end of this checklist and have the checklist printed on or attached to the approved plans for the project.
4. Unless verification is by PRMD is noted, prior to final inspection by the Building Division, PRMD Building Inspector shall complete **Column 3** and shall provide verification of completion prior to final inspection by PRMD staff.

¹ Projected to be 1/1/2014.

² 1,000 s.f. beginning on the effective date of the 2013 California Building Standards Code

³ \$200,000 beginning on the effective date of the 2013 California Building Standards Code.

<p align="center">Column 1 Feature or Measure</p> <p align="center">NOTE <i>Measures are only required for those portions of the building being added to or altered within the scope of the permitted work. (see 2010 CALGreen 5.701.1)</i></p>	<p align="center">Column 2 Mandatory Project Requirements</p> <p align="center">Section 5.701.1. Select all applicable measures below</p>	<p align="center">Column 3 Verification <i>Complete after implementation and prior to final inspection approval</i> Verification by Building Inspector or by Plan Check staff as noted</p>
<p align="center">DIVISION 5.7 - ADDITIONS AND ALTERATIONS TO EXISTING NONRESIDENTIAL BUILDINGS</p>		
<p>PLANNING & DESIGN</p>	<p align="center">Select all applicable measures for the project.</p>	<p align="center">Select all measures verified in the completed project.</p>
<p>5.710.6 Storm water pollution prevention. <u>Additions</u> that disturb less than one acre of land shall prevent the pollution of stormwater runoff from construction activities.</p>	<p align="center"><input type="checkbox"/></p>	<p align="center">Plan Check Staff <input type="checkbox"/></p>
<p>5.710.6.2 Bicycle parking. Comply with Sections 5.710.6.2.1 and 5.710.6.2.2.</p> <p>5.710.6.2.1 Short-term bicycle parking. If the project is anticipated to generate visitor traffic that add 10 or more vehicular parking spaces, provide permanently anchored bicycle racks within 200 feet of the visitors' entrance, readily visible to passers-by, for 5% of the additional visitor motorized vehicle parking capacity, with a minimum of one two-bike capacity rack.</p> <p>5.710.6.2.2 Long-term bicycle parking. For buildings with over 10 tenant-occupants that add 10 or more vehicular parking spaces, provide secure bicycle parking for 5% of the additional motorized vehicle parking capacity, with a minimum of one space.</p>	<p align="center"><input type="checkbox"/></p> <p align="center"><input type="checkbox"/></p>	<p align="center">Building Inspector <input type="checkbox"/></p> <p align="center"><input type="checkbox"/></p>
<p>5.710.6.3 Designated parking for fuel-efficient vehicles. For <u>projects that add 10 or more vehicular parking spaces</u>, provide designated parking for any combination of low-emitting, fuel-efficient, and carpool/van pool vehicles as shown in Table 5.106.2.2 of Division 5.1 based on the number of additional spaces.</p> <p>5.710.6.3.1 Parking stall marking. If applicable above, paint the following characters such that the lower edge of the last word aligns with the end of the stall striping and is visible beneath a parked vehicle: “ CLEAN AIR /VANPOOL / EV “</p>	<p align="center"><input type="checkbox"/></p> <p align="center"><input type="checkbox"/></p>	<p align="center">Building Inspector <input type="checkbox"/></p> <p align="center"><input type="checkbox"/></p>
<p>5.710.6.10 Grading and Paving. For <u>projects involving grading or paving</u>, Construction plans shall indicate how site grading or a drainage system will manage all surface water flows to keep water from entering buildings. Examples of methods to manage surface water include those shown below:</p> <ol style="list-style-type: none"> 1. Swales. 2. Water collection and disposal systems. 3. French drains 4. Water retention gardens 5. Other water measures which keep surface water away from buildings and aid in groundwater recharge. 	<p align="center"><input type="checkbox"/></p>	<p align="center">Plan Check Staff <input type="checkbox"/></p>

<p align="center">Column 1 Feature or Measure</p> <p align="center">NOTE Measures are only required for those portions of the building being added to or altered within the scope of the permitted work. <i>(see 2010 CALGreen 5.701.1)</i></p>	<p align="center">Column 2 Mandatory Project Requirements</p> <p align="center">Section 5.701.1. Select all applicable measures below</p>	<p align="center">Column 3 Verification <i>Complete after implementation and prior to final inspection approval</i> Verification by Building Inspector or by Plan Check staff as noted</p>
<p>WATER EFFICIENCY AND CONSERVATION</p>		
<p>5.712.3 Indoor water use.</p> <p>5.712.3.1 Meters. Separate submeters or metering device shall be installed for the uses described in Sections 5.712.3.1.1 and 5.713.3.1.2 below.</p> <p>5.712.3.1.1 Additions to existing buildings in excess of 50,000 square feet. Separate submeters shall be installed as follows:</p> <ol style="list-style-type: none"> 1. For each individual leased, rented, or other tenant space within the building projected to consume more than 100 gal/day. 2. Where separate submeters for individual building tenants are unfeasible, for water supplied to the following subsystems: <ol style="list-style-type: none"> a. Makeup water for cooling towers where flow through is greater than 500 gpm. b. Makeup water for evaporative coolers greater than 6 gpm. c. Steam and hot-water boilers with energy input more than 500,000 Btuh (147 kW) <p>5.712.3.1.2 Excess consumption. Any project or space within a building that is projected to consume more than 1,000 gal/day.</p>	<p align="center"><input type="checkbox"/></p> <p align="center"><input type="checkbox"/></p>	<p align="center">Building Inspector</p> <p align="center"><input type="checkbox"/></p> <p align="center">Building Inspector</p> <p align="center"><input type="checkbox"/></p>
<p>5.712.3.2 20% water savings. A schedule of any <u>newly installed plumbing fixtures and fixture fittings within the area of the addition or alteration</u> that will reduce the overall use of potable water within the building by 20 percent shall be provided. (Calculate savings by Water Use Worksheets – WS-1 and WS-3.) . (Support documentation required at application submittal)</p>	<p align="center"><input type="checkbox"/></p>	<p align="center">Building Inspector</p> <p align="center"><input type="checkbox"/></p>
<p>5.712.3.3 Multiple showerheads serving one shower. When a shower is served by <u>more than one newly installed showerhead</u>, the combined flow rate of all of the showerheads shall not exceed the maximum flow rates specified in the 20 percent reduction column contained in table 5.303.2.3 or the shower shall be designed to only allow one showerhead to be in operation at a time.</p>	<p align="center"><input type="checkbox"/></p>	<p align="center">Building Inspector</p> <p align="center"><input type="checkbox"/></p>
<p>5.712.3.5 Plumbing fixtures and fittings. <u>Newly installed plumbing fixtures</u> (water closets and urinals) and fittings and showerheads) shall meet the standards referenced in Table 5.503.6 of Division 5.3.</p>	<p align="center"><input type="checkbox"/></p>	<p align="center">Building Inspector</p> <p align="center"><input type="checkbox"/></p>

<p align="center">Column 1 Feature or Measure</p> <p align="center">NOTE <i>Measures are only required for those portions of the building being added to or altered within the scope of the permitted work. (see 2010 CALGreen 5.701.1)</i></p>	<p align="center">Column 2 Mandatory Project Requirements</p> <p align="center">Section 5.701.1. Select all applicable measures below</p>	<p align="center">Column 3 Verification <i>Complete after implementation and prior to final inspection approval</i> Verification by Building Inspector or by Plan Check staff as noted</p>
<p>5.712.4 Outdoor Water Use</p> <p>5.712.4.1 Water budget. A water budget shall be developed for landscape irrigation use installed in conjunction with an addition or alteration.</p> <p>5.712.4.2. Outdoor potable water use. For building additions or alterations requiring <u>upgraded water service for landscaped areas of at least 1,000 square feet but not more than 5,000 square feet</u> (the level at which Water Code §535 applies), separate submeters or metering devices shall be installed for outdoor potable water use.</p> <p>5.712.4.3 Irrigation design. In building additions or alterations with <u>at least 1,000 square feet but not more than 2500 square feet of cumulative added or altered landscaped area</u> (the level at which the MLO applies), install irrigation controllers and sensors which include the following criteria, and meet manufacturer's recommendations.</p> <p>5.712.4.3.1 Irrigation controllers. Automatic irrigation system controllers installed at the time of final inspection shall comply with the following:</p> <ol style="list-style-type: none"> 1. Controllers shall be weather- or soil moisture-based controllers that automatically adjust irrigation in response to changes in plants' needs as weather conditions change. 2. Weather-based controllers without integral rain sensors or communication systems that account for local rainfall shall have a separate wired or wireless rain sensor which connects or communicates with the controller(s). Soil moisture-based controllers are not required to have rain sensor input. 	<p align="center"><input type="checkbox"/></p> <p align="center"><input type="checkbox"/></p> <p align="center"><input type="checkbox"/></p> <p align="center"><input type="checkbox"/></p>	<p align="center">Building Inspector</p> <p align="center"><input type="checkbox"/></p> <p align="center"><input type="checkbox"/></p> <p align="center"><input type="checkbox"/></p> <p align="center"><input type="checkbox"/></p>
MATERIAL CONSERVATION AND RESOURCE EFFICIENCY		
<p>5.713.7 Weather resistance and moisture management.</p> <p>5.713.7.1 Weather protection. When <u>adding or altering an exterior wall or foundation</u>, provide a weather-resistant exterior wall and foundation envelope as required by California Building Code Section 1403.2 (Weather Protection) and California Energy Code Section 150 (mandatory Features and Devices), manufacturer's installation instructions, or local ordinance, whichever is more stringent.</p>	<p align="center"><input type="checkbox"/></p>	<p align="center">Building Inspector</p> <p align="center"><input type="checkbox"/></p>
<p>5.713.7.2 Moisture control. When <u>adding or altering irrigation sprinklers or entries and openings to a building</u>, employ moisture control measures by the following methods:</p> <p>5.713.7.2.1 Sprinklers. Prevent irrigation spray on structures.</p> <p>5.713.7.2.2 Entries and openings. Design exterior entries and/or openings subject to foot traffic or wind-driven rain to prevent water intrusion into buildings.</p>	<p align="center"><input type="checkbox"/></p> <p align="center"><input type="checkbox"/></p>	<p align="center">Building Inspector</p> <p align="center"><input type="checkbox"/></p> <p align="center"><input type="checkbox"/></p>

<p align="center">Column 1 Feature or Measure</p> <p align="center">NOTE Measures are only required for those portions of the building being added to or altered within the scope of the permitted work. (see 2010 CALGreen 5.701.1)</p>	<p align="center">Column 2 Mandatory Project Requirements</p> <p align="center">Section 5.701.1. Select all applicable measures below</p>	<p align="center">Column 3 Verification <i>Complete after implementation and prior to final inspection approval</i> Verification by Building Inspector or by Plan Check staff as noted</p>
<p>CONSTRUCTION WASTE REDUCTION, DISPOSAL AND RECYCLING</p>		
<p>5.713.8 Construction waste reduction, disposal and recycling.</p> <p>5.713.8.1 Construction waste management. Recycle and/or salvage for reuse a minimum of 50% of the nonhazardous construction waste in accordance with Section 5.713.8.1.1 or 5.713.8.1.2; or meet a local construction and demolition waste management ordinance, whichever is more stringent.</p> <p>5.713.8.1.1 Construction waste management plan. Submit a construction waste management plan that complies with Items 1 through 4 of Section 5.713.8.1.1. (Support documentation required prior to permit issuance)</p> <p>5.713.8.1.2 Waste management company. Utilize a waste management company that can provide verifiable documentation that the percentage of construction waste material diverted from the landfill complies with this section.</p> <p>Exceptions to Sections 5.713.8.1.1 and 5.713.8.1.2:</p> <ol style="list-style-type: none"> 1. Excavated soil and land-clearing debris 2. Alternate waste reduction methods developed by working with local agencies if diversion or recycle facilities capable of compliance with this item do not exist. 3. Demolition waste meeting local ordinance or calculated in consideration of local recycling facilities and markets, where demolition of an existing structure(s) is necessary for the new construction. <p>5.713.8.1.3 Documentation. Documentation shall be provided to the enforcing agency which demonstrates compliance with Section 5.713.8.1.1, Items 1 through 4. The waste management plan shall be updated as necessary and shall be accessible during construction for examination by the enforcing agency. (Support documentation required prior to permit issuance)</p> <p>5.713.8.3 Excavated soil and land clearing debris. 100% of trees, stumps, rocks and associated vegetation and soils resulting primarily from land clearing shall be reused or recycled. For a phased project, such material may be stockpiled on site until the storage site is developed.</p> <p>Exception: Reuse, either on-or off-site, of vegetation or soil contaminated by disease or pest infestation.</p>	<p align="center"><input type="checkbox"/></p> <p align="center"><input type="checkbox"/></p> <p align="center"><input type="checkbox"/></p> <p align="center"><input type="checkbox"/></p> <p align="center"><input type="checkbox"/></p> <p align="center"><input type="checkbox"/></p>	<p align="center">Building Inspector (all)</p> <p align="center"><input type="checkbox"/></p> <p align="center"><input type="checkbox"/></p> <p align="center"><input type="checkbox"/></p> <p align="center"><input type="checkbox"/></p> <p align="center"><input type="checkbox"/></p>
<p>5.713.10 Building maintenance and operation.</p> <p>5.713.10.1 Recycling by occupants. If not provided on the existing site and <u>where site conditions permit</u>, provide readily accessible areas that serve the entire building and are identified for the depositing, storage, and collection of nonhazardous materials for recycling <u>if additions or alterations were conducted or applied for within a 12 month period resulting in an increase of 30 percent or more in floor area</u> (see items 1 through 3 of Section 5.713.10.1).</p>	<p align="center"><input type="checkbox"/></p>	<p align="center">Building Inspector</p> <p align="center"><input type="checkbox"/></p>

<p style="text-align: center;">Column 1 Feature or Measure</p> <p style="text-align: center;">NOTE <i>Measures are only required for those portions of the building being added to or altered within the scope of the permitted work. (see 2010 CALGreen 5.701.1)</i></p>	<p style="text-align: center;">Column 2 Mandatory Project Requirements</p> <p style="text-align: center;">Section 5.701.1. Select all applicable measures below</p>	<p style="text-align: center;">Column 3 Verification <i>Complete after implementation and prior to final inspection approval</i> Verification by Building Inspector or by Plan Check staff as noted</p>
<p>5.713.10.4 Testing and adjusting. <u>New systems installed to serve an addition or alteration</u> shall be tested and adjusted. New systems include HVAC systems and controls, indoor and outdoor lighting and controls, water heating systems, renewable energy systems, landscape irrigation systems and water reuse systems.</p> <p>5.713.10.4.2 Systems. Develop a written plan of procedures for testing and adjusting systems. Systems to be included for testing and adjusting shall include, as applicable to the project, the systems listed in Section 5.713.10.4.2: 1-6</p> <p>5.713.10.4.3 Procedures. Perform testing and adjusting procedures in accordance with manufacturer's specifications and applicable standards on each system.</p> <p>5.713.10.4.3.1 HV AC balancing. In addition to testing and adjusting, before a new space-conditioning system serving a building or space is operated for normal use, balance the system in accordance with the procedures defined by national standards listed in Section 5.713.10.4.3.1 or as approved by the enforcing agency.</p> <p>5.713.10.4.4 Reporting. After completion of testing, adjusting and balancing, provide a final report of testing signed by the individual responsible for performing these services.</p> <p>5.713.10.4.5 Operation and maintenance manual. Provide the building owner or representative with detailed operating and maintenance instructions and copies of guaranties/warranties for each added or altered system prior to final inspection.</p> <p>5.713.10.4.5.1 Inspections and reports. Include a copy of all inspection verifications and reports required by the enforcing agency.</p>	<p style="text-align: center;"><input type="checkbox"/></p> <p style="text-align: center;"><input type="checkbox"/></p> <p style="text-align: center;"><input type="checkbox"/></p> <p style="text-align: center;"><input type="checkbox"/></p> <p style="text-align: center;"><input type="checkbox"/></p> <p style="text-align: center;"><input type="checkbox"/></p> <p style="text-align: center;"><input type="checkbox"/></p>	<p style="text-align: center;">Building Inspector (all)</p> <p style="text-align: center;"><input type="checkbox"/></p> <p style="text-align: center;"><input type="checkbox"/></p> <p style="text-align: center;"><input type="checkbox"/></p> <p style="text-align: center;"><input type="checkbox"/></p> <p style="text-align: center;"><input type="checkbox"/></p> <p style="text-align: center;"><input type="checkbox"/></p>
<p>ENVIRONMENTAL QUALITY</p>		<p style="text-align: center;">Building Inspector to Verify all Environmental Quality measures</p>
<p>5.714.3 Fireplaces.</p> <p>5.714.3.1 General (Fireplaces). Install only a direct-vent sealed-combustion gas fireplace or wood-burning appliance complying with EPA Phase II emission limits.</p>	<p style="text-align: center;"><input type="checkbox"/></p>	<p style="text-align: center;"><input type="checkbox"/></p>

<p align="center">Column 1 Feature or Measure</p> <p align="center">NOTE <i>Measures are only required for those portions of the building being added to or altered within the scope of the permitted work. (see 2010 CALGreen 5.701.1)</i></p>	<p align="center">Column 2 Mandatory Project Requirements</p> <p align="center"><i>Section 5.701.1. Select all applicable measures below</i></p>	<p align="center">Column 3 Verification <i>Complete after implementation and prior to final inspection approval</i> Verification by Building Inspector or by Plan Check staff as noted</p>
POLLUTANT CONTROL		
<p>5.714.4 Pollutant Control.</p> <p>5.714.4.1 Temporary ventilation. If the HV AC system serving the added or altered area(s) is used during construction, use return air filters with a MERV of 8, based on ASHRAE 52.2-1999, or an average efficiency of 30% based on ASHRAE 52.1-1992. Replace all filters of the HV AC system serving the added or altered area(s) immediately prior to occupancy.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p>5.714.4.3 Covering of duct openings and protection of mechanical equipment during construction. At the time of rough installation and during storage on the construction site and until final startup of the heating, cooling and ventilating equipment, all duct and other related air distribution component openings shall be covered with tape, plastic, sheetmetal or other methods acceptable to the enforcing agency to reduce the amount of dust, water and debris which may enter the system.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p>5.714.4.4 Finish material pollutant control. <u>Newly installed finish materials</u> shall comply with Sections 5.714.4.4.1 through 5.714.4.4.4.</p> <p>5.714.4.4.1 Adhesives, sealants, caulks. <u>Newly installed</u> adhesives and sealants used on the project shall meet the requirements of the following standards.</p> <ol style="list-style-type: none"> 1. Adhesives, adhesive bonding primers, adhesive primers, sealants, sealant primers, and caulks shall comply with local or regional air pollution control or air quality management district rules where applicable, or SCAQMD Rule 1168 VOC limits, as shown in Tables 5.504.4.1 and 5.504.4.2. in Division 5 2. Aerosol adhesives, and smaller unit sizes of adhesives, and sealant or caulking compounds (in units of product, less packaging, which do not weigh more than one pound and do not consist of more than 16 fluid ounces) shall comply with statewide VOC standards and other requirements, including prohibitions on use of certain toxic compounds, of California Code of Regulations, Title 17, commencing with Section 94507. 	<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/>
<p>5.714.4.4.3 Paints and coatings. <u>Newly installed architectural paints and coatings</u> shall comply with Table 5.504.4.3 in Division 5.5.</p> <p>5.714.4.4.3.1 Aerosol Paints and Coatings. <u>Newly installed aerosol paints and coatings</u> shall meet the Product-Weighted MIR Limits for ROC in section 94522(a)(3) and other requirements, including prohibitions on use of certain toxic compounds and ozone depleting substances (CCR, Title 17, Section 94520 et seq).</p> <p>5.714.4.4.3.2 Verification. Verification of compliance with this section shall be provided when requested by the enforcing agency.</p>	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>

<p style="text-align: center;">Column 1 Feature or Measure</p> <p style="text-align: center;">NOTE Measures are only required for those portions of the building being added to or altered within the scope of the permitted work. (see 2010 CALGreen 5.701.1)</p>	<p style="text-align: center;">Column 2 Mandatory Project Requirements</p> <p style="text-align: center;">Section 5.701.1. Select all applicable measures below</p>	<p style="text-align: center;">Column 3 Verification <i>Complete after implementation and prior to final inspection approval</i> Verification by Building Inspector or by Plan Check staff as noted</p>
<p>5.714.4.4.4 Carpet systems. All <u>newly installed carpet</u> in the building interior shall meet the testing and product requirements of one of the standards listed in Section 5.714.4.4.4.</p> <p>5.714.4.4.4.1 Carpet cushion. All <u>newly installed carpet cushion</u> in the building interior shall meet the requirements of the Carpet and Rug Institute Green Label program.</p> <p>5.714.4.4.4.2 Carpet adhesive. All <u>newly installed carpet adhesive</u> shall meet the requirements of Table 5.504.4.1 in Division 5.5.</p>	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
<p>5.714.4.4.5 Composite wood products. <u>Newly installed</u> hardwood plywood, particleboard, and medium density fiberboard composite wood products used on the interior or exterior of the building shall meet the requirements for formaldehyde as specified in Table 5.504.4 in Division 5.5.</p> <p>5.714.4.4.5.2 Documentation. Verification of compliance with this section shall be provided when requested by the enforcing agency. Documentation shall include at least one of the following as applicable.</p> <ol style="list-style-type: none"> 1. Product certifications and specifications. 2. Chain of custody certifications. 3. Product labeled and invoiced as meeting the Composite Wood Products regulation (see CCR, Title 17, Section 93120, et seq.) 4. Exterior grade products marked as meeting the PS-I or PS-2 standards of the Engineered Wood Association, the Australian AS/NZS 2269 or European 636 3S standards. 5. Other methods acceptable to the enforcing agency. 	<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/>
<p>5.714.4.4.6 Resilient flooring systems. For 50% of floor area receiving <u>newly installed resilient flooring</u>, install resilient flooring complying with the VOC-emission limits defined in the 2009 CHPS criteria and listed on its High Performance Products Database; products compliant with CHPS criteria certified under the Greenguard Children & Schools program; certified under the FloorScore program of the Resilient Floor Covering Institute; or meet California Department of Public Health 2010 Specification 01350.</p> <p>5.714.4.4.6.1 Verification of compliance. Documentation shall be provided verifying that resilient flooring materials meet the pollutant emission limits. (Support documentation required prior to final inspection approval)</p>	<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/>
<p>5.714.4.5.3 Filters. In <u>mechanically ventilated spaces serving additions or altered areas</u> of buildings, provide regularly occupied areas of the building with air filtration media for outside and return air that provides at least a MERV of 8. MERV 8 filters shall be installed prior to occupancy, and recommendations for maintenance with filters of the same value shall be included in the operation and maintenance manual.</p> <p>Exception: A MERV -1 filter shall be allowed for return air only or return with prefiltered outsideair, if the filter is of are-usable, nondisposable type, and the fan energy use of that air delivery system is 0.4W/cfm or less at design airflow.</p>	<input type="checkbox"/>	<input type="checkbox"/>

<p align="center">Column 1 Feature or Measure</p> <p align="center">NOTE Measures are only required for those portions of the building being added to or altered within the scope of the permitted work. (see 2010 CALGreen 5.701.1)</p>	<p align="center">Column 2 Mandatory Project Requirements</p> <p align="center">Section 5.701.1. Select all applicable measures below</p>	<p align="center">Column 3 Verification <i>Complete after implementation and prior to final inspection approval</i> Verification by Building Inspector or by Plan Check staff as noted</p>
<p>5.714.4.7 Environmental tobacco smoke (ETS) control. <u>Where outdoor areas are provided for smoking</u>, prohibit smoking within 25 feet of building entries, outdoor air intakes and operable windows and within the building as already prohibited by <u>other laws or regulations</u>; or as enforced by ordinances, regulations, or policies of any city or county, whichever are more stringent. See Santa Rosa City Code Chapter 9-20.</p>	<p align="center"><input type="checkbox"/></p>	<p align="center"><input type="checkbox"/></p>
<p>5.714.5 Indoor moisture control.</p> <p>5.714.5.1 Indoor moisture control. Additions or altered spaces within buildings shall meet or exceed the provisions of California Building Code, CCR, Title 24, Part 2, Sections 1203 (Ventilation) and Chapter 14 (Exterior Walls). For additional measures not applicable to low-rise residential occupancies, see Section 5.407.2.</p>	<p align="center"><input type="checkbox"/></p>	<p align="center"><input type="checkbox"/></p>
<p>5.714.6 Indoor air quality.</p> <p>5.714.6.1 Outside air delivery. <u>Where newly installed, mechanically or naturally ventilated spaces in additions or altered spaces</u> within buildings, shall meet the minimum requirements of Section 121 of the California Energy Code and Chapter 4 of CCR, Title 8, or the applicable local code, whichever is more stringent.</p> <p>5.714.6.2 Carbon dioxide (CO₂) monitoring. For <u>additions equipped with demand control ventilation</u>, CO₂ sensors and ventilation controls shall be specified and installed in accordance with the requirements of the latest edition of the California Energy Code, Section 121(c).</p>	<p align="center"><input type="checkbox"/></p> <p align="center"><input type="checkbox"/></p>	<p align="center"><input type="checkbox"/></p> <p align="center"><input type="checkbox"/></p>

<p style="text-align: center;">Column 1 Feature or Measure</p> <p style="text-align: center;">NOTE Measures are only required for those portions of the building being added to or altered within the scope of the permitted work. (see 2010 CALGreen 5.701.1)</p>	<p style="text-align: center;">Column 2 Mandatory Project Requirements</p> <p>Section 5.701.1. Select all applicable measures below</p>	<p style="text-align: center;">Column 3 Verification <i>Complete after implementation and prior to final inspection approval</i> Verification by Building Inspector or by Plan Check staff as noted</p>
<p>5.714.7 Environmental comfort.</p> <p>5.714.7.1 Acoustical control. Employ building assemblies and components with STC values determined in accordance with ASTM E 90 and ASTM E 413 or OITC determined in accordance with ASTM E 1332, using either the prescriptive or performance method in Section 5.714.7.1.1 or 5.714.7.1.2. (Support documentation required prior to permit issuance)</p> <p>5.714.7.1.1 Exterior noise transmission, <u>Prescriptive Method</u>. Wall and floor-ceiling assemblies exposed to the noise source making up the building envelope shall have exterior wall and roof-ceiling assemblies meeting a composite STC rating of at least 50 or a composite OITC rating of no less than 40 with exterior windows of a minimum STC of 40 <u>or</u> OITC of 30 in the locations described in Items 1 and 2.</p> <p>5.714.7.1.1.1 Noise exposure where noise contours are not readily available. Buildings exposed to a noise level of 65 dB L_{eq}-1Hr during any hour of operation shall have exterior wall and roof-ceiling assemblies exposed to the noise source meeting a composite STC or rating of at least 45 (or OITC 35), with exterior windows of a minimum STC of 40 (or OITC 30).</p> <p>or</p> <p>5.714.7.1.2 Exterior noise transmission, <u>Performance Method</u>. For buildings located as defined in Sections A5.714.7.1.1 or A5. 714.7.1.1.1, wall and roof-ceiling assemblies making up the building envelope shall be constructed to provide an interior noise environment attributable to exterior sources that does not exceed an hourly equivalent noise level (L_{eq}-1Hr) of 50 dBA in occupied areas during any hour of operation.</p> <p>5.714.7.1.2.1 Documentation of compliance. An acoustical analysis documenting complying interior sound levels shall be prepared by personnel approved by the architect or engineer of record.</p>	<p style="text-align: center;"><input type="checkbox"/></p> <p style="text-align: center;"><i>Choose either Prescriptive or Performance method</i></p> <p style="text-align: center;"><input type="checkbox"/></p> <p style="text-align: center;"><input type="checkbox"/></p> <p style="text-align: center;">or</p> <p style="text-align: center;"><input type="checkbox"/></p> <p style="text-align: center;"><input type="checkbox"/></p>	<p style="text-align: center;"><input type="checkbox"/></p> <p style="text-align: center;"><i>Verify either Prescriptive or Performance method</i></p> <p style="text-align: center;"><input type="checkbox"/></p> <p style="text-align: center;"><input type="checkbox"/></p> <p style="text-align: center;">or</p> <p style="text-align: center;"><input type="checkbox"/></p> <p style="text-align: center;"><input type="checkbox"/></p>
<p>5.714.7.1.3 Interior sound transmission. <u>Newly installed wall and floor-ceiling assemblies separating tenant spaces and public places</u> shall have an STC of at least 40.</p>	<p style="text-align: center;"><input type="checkbox"/></p>	<p style="text-align: center;"><input type="checkbox"/></p>
<p>5.714.8 Outdoor air quality.</p> <p>5.714.8.1 Ozone depletion and greenhouse gas reductions. <u>New installations of HVAC, refrigeration, and fire suppression equipment</u> shall comply with Sections 5.714.8.1.1 and 5.714.8.1.2 below.</p> <p>5.714.8.1.1 Chlorofluorocarbons (CFCs). Install HVAC, refrigeration and fire suppression equipment that does not contain CFCs.</p> <p>5.714.8.1.2 Halons. Install HVAC, refrigeration and fire suppression equipment that do not contain Halons.</p>	<p style="text-align: center;"><input type="checkbox"/></p> <p style="text-align: center;"><input type="checkbox"/></p> <p style="text-align: center;"><input type="checkbox"/></p>	<p style="text-align: center;"><input type="checkbox"/></p> <p style="text-align: center;"><input type="checkbox"/></p> <p style="text-align: center;"><input type="checkbox"/></p>

INSTALLER AND SPECIAL INSPECTOR QUALIFICATIONS	<i>All checked items are required for the project</i>	<i>Select all measures verified in the completed project</i>
Qualifications		
<p>702.1 HVAC system installers (if any) are trained and certified in the proper installation of HVAC systems.</p>	<input checked="" type="checkbox"/>	<p>Building Inspector</p> <input type="checkbox"/>
Verifications		
<p>703.1 Verification of compliance with CALGreen for Nonresidential Additions and Alterations may include construction documents, plans, specifications builder or installer certification, inspection reports, or other methods acceptable to the enforcing agency which show substantial conformance. Implementation verification shall be submitted to the Building Department after implementation of all required measures and prior to final inspection approval.</p>	<input checked="" type="checkbox"/>	<p>Building Inspector</p> <input type="checkbox"/>

Green Building Acknowledgments

Project Address: _____

Project Description: _____

Section 1 - Design Verification

Complete all lines of Section 1- "Design Verification" and submit the completed checklist (Columns 1 and 2) with the plans and building permit application to the Building Department.

The owner, design professional and CALGreen special inspector have reviewed the plans and certify that the items checked above are hereby incorporated into the project plans and will be implemented into the project in accordance with the requirements set forth in the 2010 California Green Building Standards Code.

Owner's Signature

Date

Owner Name (Please Print)

Design Professional's Signature

Date

Design Professional's Name (Please Print)

PRMD Building Plans Examiner's Signature

Date

PRMD Building Plans Examiner (Please Print)

Phone

Section 2 - Implementation Verification

Complete, sign and submit the completed checklist, including Column 3, together with all original signatures on Section 2 – "Implementation Verification" to the Building Division prior to Building Division final inspection.

I have inspected the work have received sufficient documentation to verify and certify that the project identified above was constructed in accordance with this Green Building Checklist and in accordance with the requirements set forth in the 2010 California Green Building Standards Code.

PRMD Building Inspector's Signature

Date

PRMD Building Inspector's Name (Please Print)

Phone (if different than above)