



**COUNTY OF SONOMA
DEPARTMENT OF TRANSPORTATION & PUBLIC WORKS**

ADDENDUM NO. 01

SUBJECT: Addendum Number 01 to EVENT ID SC001-0000001103
2020 Culvert Replacement Program, County Project No. C20302
DATE: May 11, 2020

This addendum is issued to furnish information that is supplemental to, will clarify, or modify the above-referenced solicitation.

1. For instructions on registering at the County of Sonoma Supplier Portal and submitting bids, please refer to the instructions on "How to Use the Portal", at the following URL:

<https://esupplier.sonomacounty.ca.gov/psp/FN92PRD/SUPPLIER/ERP/h/?tab=DEFAULT>

THERE IS NO IN-PERSON PUBLIC BID OPENING. The public bid opening will be conducted via a Webex meeting. To participate, use the following access details: Join Webex Meeting:

Monday, May 18 2020 2:00 pm - 3:30 pm

<https://sonomacounty.webex.com/sonomacounty/j.php?MTID=m2e56863dfde314f814a6745f3a0084a2>

Meeting Number: 968 455 145

Meeting Password: 2zTXVxY4MF3

You can also call into the meeting by dialing the phone number below and entering the access code. Phone
+1-408-418-9388 United States Toll
Access code: 968 455 145

Technical Questions/Clarifications

1. Line item 5 for flagging has a unit FA. What does this stand for, and how is that item being paid or bid on with the \$20,000 already in the total?
A1 Please see Section 2-1.32 BID PRICE FOR FLAGGING and Section 12, Temporary Traffic Control.
2. Line item 6 for Portable Changeable Message Signs has a quantity of 50. Are you wanting a price for 50 message boards per day?
A2 This item is paid for EA-DY.

3. Line item 33 for Guarantee. I am not finding a place in the specs that clarifies the guarantee required.

A3 Please see Bid Book_C20302.pdf, BB-25.

4. Section 14-6.03D Contractor Supplied Biologist; paragraph state to survey Skillman Lane? Please clarify if we are responsible to provide a Biologist to survey each site prior to beginning work, or will the County provide these services?

A4 Please see Section 5-1.20B(1). Comply with PLACS. Contractor shall comply with all permit provisions.

5. Clarify if #4 rebar traffic mat is required to be installed in backfill?

A5 Please see Plans_C20302.pdf. Traffic mat is required if cover is less than 12 inches.

6. Are contractors allowed to work concurrently on more than one site at a time?

A6 Yes, construction must be completed in 30 working days.

Changes to Bid Book

1. Replace BB-3 with ADD-01 BB-3. Bid Item 6, Portable Changeable Message Signs has been revised to be paid EA-DY. Contractor-Supplied Biologist (Day) has been revised to quantity 30.00.

2. Replace BB-22 with ADD-01 BB-22. Bid Item 6, Portable Changeable Message Signs has been revised to be paid EA-DY. Contractor-Supplied Biologist (Day) has been revised to quantity 30.00.

Changes to Special Provisions

1. Replace NTB2 with ADD-01 NTB2. Engineer's Estimate has been revised to \$731,002.00.

2. Replace BIL1 with ADD-01 BIL1. Bid Item 6, Portable Changeable Message Signs has been revised to be paid EA-DY. Contractor-Supplied Biologist (Day) has been revised to quantity 30.00.

3. Replace "Add to section 5-1.20B(1) with:", on page 13 of Special_Provisions_C20302.pdf, with:
Add to section 5-1.20B(1) with:

Comply with PLACs. United State Army Corps of Engineers 404, California Department of Fish and Wildlife Lake or Streambed Alteration, Regional Water Board 401 Certification 5C Program, and California Coastal Commission. Contractor shall comply with all permit provisions.

All other terms and conditions of RFP No. SC001-0000001103 remain unchanged.

Please sign and date below as acknowledgment of receipt of Addendum No. 01 and include with your submittal.

Signature & Date: Tyler Lawson 5/18/2020

Printed Name: Tyler Lawson

Firm: Diamond D Construction, LLC